

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 15.03.2024

It is certified that an inspection team headed by Dr. Sanjay Bajaj (B.M.O.)

(Name of Officers with designation) from Civil Hospital Jwalamukhi PHED

inspected the Laureate Global School, Kathog

(Name & Address of the school) on 11.03.2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 2517 dated 07.03.2024

of JSV Dehra (PHED Lab) certified that the


Laureate Global School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 15.03.2025

Signature with Seal: 
Name BLOCK MEDICAL OFFICER
Designation JAWALAMUKHI DISTT. KANGRA (H.P.)
Name & Address of the Office / Department :

To Principal Laureate
Global School, Kathog Jwalamukhi
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**HIMACHAL PRADESH
JAL SHAKTI VIBHAG
WATER TESTING LABORATORY JSV DEHRA**

Email:- dehralab@gmail.com

Mob.No. 8219970969

Sr. No. 2517

Detail of the Sample:- The Principal Laureate Global School Kathog

Name of Scheme:- Private Sample

Date & time of collection. 7-3-2024

Date & time of report at - 7-3-2024

Date & time Commencing of test. 7-3-2024

A. PHYSICAL PARAMETERS (Limits: Based upon BIS :10500-2012)

1	2	3	4	5	6
S.N	TEST PARAMETER	UNITS	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT (in the absence of alternative source)	TEST RESULT
1	Colour	Hazen Units	5	15	0
2	Odour		Agreeable	Agreeable	Agree
3	Taste		Agreeable	Agreeable	Agree
4	Turbidity (NTU)	NTU	1	5	1.0
5	PH		6.5-8.5	No relaxation	7.37

B. CHEMICAL PARAMETERS (Limits: Based upon BIS : 10500-2012)

6	TDS/Elec. Conductivity	Mg/l	500	2000	210
07	Total Alkalinity	Mg/l	200	600	188
8	Chlorides (as Cl)	Mg/l	250	1000	19
9	Total Hardness	Mg/l	200	600	160
10	Magnesium	Mg/l	30	100	12
11	Calcium	Mg/l	75	200	44
12	Free Residual Chlorine	Mg/l	0.2	1	0.2
13	Total Coliforms	Number/100	Nil	Nil	0

Note: Indicate discrete sampling. Water quality monitoring to be continued only if these are traced in drinking water sources.

1. Sample will be stored for a period of 3 days from the date of issue of report.
2. Results refer only to tested samples and parameters tested.
3. This report should not be produced partially or fully without approval of the signatory for legal purposes.
4. 12 and 13 test parameters are not recognised by the NABL body.

Vns
Assistant Chemist



P. Inam
Assistant Engineer
JSV Sub-Division Dehra