

HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT

NO:-PWD/DEH/CB/WA/B-II/2023-24- 15825-26 Dated:- 12/2/24


To

The Principal,
Laureate Global School,
V.P.O. Kathog, Tehsil Jawalamukhi,
Distt. Kangra (H.P.)-176031.

Subject :- Building Safety certificate.


The requisite certificate is enclosed herewith for information and further necessary action.

D.A.: As above


Executive Engineer,
HPPWD Division,
Dehra.

Copy to the Assistant Engineer HPPWD Sub-Division
Jawalamukhi w.r.t. his office letter No. 1972 dated 09.02.2024 for information.

D.A.: Nil.


Executive Engineer,
HPPWD Division,
Dehra.


Building safety Certificate


The School building of Laureate Global School, V.P.O. Kathog Teh. Jawalamukhi Distt. Kangra H.P. was inspected by me with the concerned Junior Engineer. The building has neither being designed nor constructed by this department. No earthquake resistant norms have been adopted for this building. No structural drawings approved by the competent Government Agency have been produced. The structure is a Non Engineered structure. Hence the structural safety of this building cannot be ensured specially from earthquake point of view. This building is constructed in the year 2016. This department will not be responsible for any type of loss of life and property etc., if this structure fails under any circumstances. However as per visual inspection the building appears to be safe at present under static loads.

Note: The School administration shall be responsible for security of the School children's in the school complex.


Place:- Dehra

Date:- 08/02/2024


Junior Engineer,
Sub-Division J/Mukhi,
Section Chambapattan.


Assistant Engineer,
Jawalamukhi Sub-Division,
HPPWD.,Jawalamukhi .

c/s


Executive Engineer
H.P.P.W.D. Dehra,
Dehra Division,
HPPWD Dehra.